

**MAHARASHTRA JEEVAN PRADHIKARAN
WATER MANAGEMENT DIVISION AMBERNATH**

Executive Engineer,
Maharashtra Jeevan Pradhikaran
Water Management Division, Sai section,
Road No.82, Ambarnath (B.) 421501



Phone No. : 0251 - 2602348
e-mail : ejp@amb@gmail.com

No.MJPWMDn./Amb/TB-1/ 5202 /2024

Date :- 14 /10/2024

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **MILIND DESHPANDE EXECUTIVE ENGINEER** from **MAHARASHTRA JEEVAN PRADHIKARAN WATER MANAGEMENT** inspected Ryan International School – Runwal MyCity' Usarghar, Diva Manpada Road, Off Kalyan Shilphata Road, Dombivli (East) – 421201, Maharashtra on 11th October 2024 and found that the Ryan International School – Runwal MyCity' has safe drinking water facilities for the students and members of staff of the institution and is maintain the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for **ONE YEAR** for the period up to September 2025.

(Milind Deshpande)
Executive Engineer
MJP WM Dn. Ambarnath

To
Ryan International School – Runwal MyCity'
Usarghar, Diva Manpada Road,
Off Kalyan Shilphata Road,
Dombivli, (East)- 421201

Principal
Ryan International School
Runwal My-city
Usarghar, Diva Manpada Road,
Off Kalyan - Shilphata Rd,
Dombivli East, Maharashtra

Manager
Ryan International School
Runwal My-city
Usarghar, Diva Manpada Road,
Off Kalyan - Shilphata Rd,
Dombivli East, Maharashtra

TEST REPORT

Ref. No: APX-W24060028
Group: Water

DOC NO.: APX-QSF-050
ULR No. TC679724000001341F


Issued To:
Name : RYAN INTERNATIONAL SCHOOL
Address: Runwal Mycity, Usarghar, Diva Manpada Road,
Off. Kalyan Shilphata Road Dombivli East Thane 4006012

Sample Receipt Date	17 th June, 2024	Start Of Analysis	17 th June, 2024
Report Issued Date	20 th June, 2024	End Of Analysis	20 th June, 2024


Particulars of Sample Submitted	
Sample Name	DRINKING WATER
Test Reference	As Per Below Method
Quantity & Packing	2L Plastic bottle
Batch No./ Lot No.	Not Provided
Sample Submitted by/ Sample Collected by	Sample Collected By Lab Representative Mr. Satish More
Sample condition at the time of receipt	Self-Sealed.
Any Other Information	Not Provided
Sample Description	Suspended Particles Not Observed.


Analysis Results:
Discipline: Biological


Sr. No	Test Parameter	Test Method	Limit (IS 10500:2012)	Result	Unit
1.	Total Coliforms	IS 15185:2016	Should Not be Detected	Absent	/ 100 ml
2.	<i>E. coli</i>	IS 15185:2016	Should Not be Detected	Absent	/ 100 ml



Principal
Ryan International School
Runwal My-city
Usarghar, Diva Manpada Road,
Off Kalyan - Shilphata Rd,
Dombivli East, Maharashtra


Manager
Ryan International School
Runwal My-city
Usarghar, Diva Manpada Road,
Off Kalyan - Shilphata Rd,
Dombivli East, Maharashtra




Prepared By
Harsh Bhosle (Report Executive)


Reviewed By
Karishma Golungulu (Sr. Microbiologist)


Authorized Signatory
Sujata Bagad (TM- Microbiology)



TEST REPORT

Ref. No: APX-W24060028
Group: Water
Discipline: Chemical

DOC NO.: APX-QSF-050
ULR No. TC679724000001341F

Sr. No	Test Parameter	Test Method	Limit (IS 10500:2012)	Result	Unit
1.	Colour	IS:3025 (P-4) : 2021	5 max	<1.0	CU
2.	Odour	IS:3025 (P-5) : 2018	Agreeable	Agreeable	-
3.	Taste	IS:3025 (P-8) : 2023	Agreeable	Agreeable	-
4.	Turbidity	IS:3025 (P-10) : 2023	1 max	<0.1	NTU
5.	pH @ 25°C	IS:3025 (P-11) : 2022	6.5 to 8.5 max	7.20	-
6.	Total Dissolved Solids	IS:3025 (P-16) : 2023	500 max	8.00	mg/l
7.	Alkalinity (as CaCO ₃)	IS:3025 (P-23) : 2023	200 max	4.1	mg/l
8.	Total Hardness (as CaCO ₃)	IS:3025 (P-21) : 2009	200 max	3.88	mg/l
9.	Chloride (as Cl)	IS:3025 (P-32) : 1988	250 max	3.68	mg/l
10.	Calcium (as Ca)	IS:3025 (P-40) : 1991	75 max	<1.0	mg/l
11.	Magnesium (as Mg)	IS:3025 (P-46) : 2023	30 max	<1.0	mg/l
12.	Sulphate (as SO ₄)	IS:3025 (P-24/ Sec -I) : 2022	200 max	<1.0	mg/l
13.	Free residual chlorine (0.2 min water is when chlorinated)	IS:3025 (P-26) : 2021	0.2 min	<0.05	mg/l

Abbreviations: N.S.- Not specified; N.A.- Not Applicable; BDL - Below Detection Limits; LOQ- Limit of Quantification; N.D.- Not Detected; N.M.T - Not More Than; INTC - Too Numerous to Count

Remarks: Sample conforms for above tested parameters as per IS 10500:2012 Amendment - 4 : 2021

Note:

- Test results are applicable to the sample/s tested as per Job ID only.
- Test Certificates shall not be reproduced without written permission of the Authorized Signatory - APX Laboratories.
- APX Laboratories is not responsible for the authenticity of photocopied or scanned reports.
- This report shall not be used for advertisement / judicial purpose.
- Supplementary Information: When required supporting documents for the measurements taken & derived like graphs, tables, sketches, photographs as appropriate test report to the customer (if any) NONE

HRB
Prepared By
Harsh Bhosle (Report Executive)


Pratiksha Bhosale
Reviewed By
Pratiksha Bhosale (Sr. Chemist)

Pravin Banagar
Authorized Signatory
Pravin Banagar (Lab Incharge)

Page 2 of 2

Principals
Principal
Ryan International School
Runwal My-city
Usarghar, Diva Manpada Road,
Off Kalyan - Shilphata Rd,
Dombivli East, Maharashtra

.....End of Report.....



Manager
Manager
Ryan International School
Runwal My-city
Usarghar, Diva Manpada Road,
Off Kalyan - Shilphata Rd,
Dombivli East, Maharashtra

APX Laboratories

Plot No. B 7/1, 27 ACRE Kothari Warehouse No. 3, S. V. Road, Chitalsar, Manpada, Thane West 400 607, MUMBAI, IND.
Contact : Mob. : +91 8879996703 / +91 9321767542 / +91 9372818009
www.apxlaboratories.com | Email : info@apxlaboratories.com

